

# Certificate of Compliance


This is to certify that

**EDGE ANALYTICAL, Inc.,**  
An Accredited Drinking Water Laboratory,  
Certification number 046, has completed the analysis of

**MOUNTAIN MIST**

“Mountain Mist Finished Product - Distilled”

on April 7, 2021, according to the FDA testing requirements for bottled drinking water.  
All parameters were found to be in compliance with 21 CFR 165 and 21 CFR 129  
published limits for bottled drinking water.



Lawrence J. Henderson, PhD  
Director of Laboratories

21-08272



Burlington, WA *Corporate Laboratory (a)*  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA *Microbiology (b)*  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology (e)*  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Mountain Mist  
5410 189th St. E  
Puyallup, WA 98375

Reference Number: **21-08272**

Authorized by:

Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Project: FDA no SOC's - Annual Finished Product (Distilled)  
Field ID: FDA Annual no SOC's  
Sample Description: Mountain Mist Finished Product - Distilled  
Sampled By:  
Sample Date: 03/10/2021

Lab Number: 16191  
Report Date: 04/07/2021  
Approved By: anp,bj,bsp,hy,mcs

### Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	ND	1.0	0.010	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	0.17	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE+NITRITE as N	0.17	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
MRL - Method Reporting Limit.

If you have any questions concerning this report contact us at the above phone number.

FORM: cFDA.rpt



Reference Number: 21-08272

Lab Number: 16191

Report Date: 04/07/2021

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	ND	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.010	mg/L	200.8	a	
14808-79-8	SULFATE	ND	250	0.2	mg/L	300.0	a	
57-12-5	CYANIDE	ND	0.2	0.005	mg/L	OIA-1677-DW	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	ND	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.00	0.050	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
MRL - Method Reporting Limit.





Reference Number: 21-08272

Lab Number: 16191

Report Date: 04/07/2021

## BOTTLED WATER STANDARD OF QUALITY REPORT

### Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-10139	HYDROGEN ION (pH)	5.56			pH Units	150.1	a	Temp (C): 23.2
E-11712	COLOR	ND	15	5	COLOR UNIT	SM2120 B	a	pH:6
E-11734	ODOR	ND	3	1	TON	SM2150	a	Temperature: 41.0
E-10617	TURBIDITY	ND	1	0.10	NTU	180.1	a	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.  
MRL - Method Reporting Limit .



**Burlington, WA Corporate Laboratory (a)**  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400

**Bellingham, WA Microbiology (b)**  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

**Portland, OR Microbiology/Chemistry (c)**  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

**Corvallis, OR Microbiology/Chemistry (d)**  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

**Bend, OR Microbiology (e)**  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

# Data Report

Client Name: Mountain Mist  
5410 189th St. E  
Puyallup, WA 98375

Reference Number: **21-08272**  
Project: FDA no SOC's - Annual  
Finished Product (Distilled)

Report Date: 4/7/21

Date Received: 3/9/21

Approved by: bsp

Authorized by:

Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Sample Description: FDA Annual no SOC's - Mountain Mist Finished Product - Distilled  
Lab Number: 16191      Sample Comment:  
Sample Type: Grab

Sample Date: 3/10/21 10:47 am  
Collected By:

CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	ND	0.5	0.02	mg/L	1.0	200.7	a	3/16/21	ANP	200.7_210316B	
E-11778	HARDNESS as Calcium Carbonate	ND	3.3	0.14	mg/L	1.0	200.7	a	3/16/21	ANP	200.7_210316B	
7439-95-4	MAGNESIUM	ND	0.5	0.02	mg/L	1.0	200.7	a	3/16/21	ANP	200.7_210316B	
7440-09-7	POTASSIUM	ND	1.0	0.06	mg/L	1.0	200.7	a	3/16/21	ANP	200.7_210316B	
7440-23-5	SODIUM	0.72	0.5	0.2	mg/L	1.0	200.7	a	3/16/21	ANP	200.7_210316B	
E-10184	ELECTRICAL CONDUCTIVITY	ND	10		uS/cm	1.0	SM2510 B	a	3/12/21	ASE	EC_210311	

Notes:  
 ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.  
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.  
 D.F. - Dilution Factor