Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,

An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

MOUNTAIN MIST

"Mountain Mist Finished Product - Spring"

on April 14, 2022, according to the FDA testing requirements for bottled drinking water.
All parameters were found to be in compliance with 21 CFR 165 and 21 CFR 129
published limits for bottled drinking water.

EDGE ANALYTICAL

Director of Laboratories, Vice President

22-07683

EDGE ANALYTICAL

Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - **800.755.9295** • 360.757.1400

Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Mountain Mist
5410 189th Street E
Puyallup, WA 98375

Reference Number: **22-07683**
Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Project: FDA Annual Product - Finished Product Spring
Field ID: FDA Annual Product
Sample Description: Mountain Mist Finished Product - Spring
Sampled By:
Sample Date: 03/07/2022

Lab Number: 14783
Report Date: 04/14/2022
Approved By: anp,bj,hy,ljh,ma,mcs,tjb

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-36-0	ANTIMONY	**ND**	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	**ND**	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	**ND**	1.0	0.010	mg/L	200.8	a	
7440-41-7	BERYLLIUM	**ND**	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	**ND**	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	**ND**	0.05	0.005	mg/L	200.8	a	
16984-48-8	FLUORIDE	**ND**	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	**ND**	0.005	0.001	mg/L	200.8	a	
7440-02-0	NICKEL	**ND**	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	**2.29**	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	**ND**	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE+NITRITE as N	**2.29**	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	**ND**	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	**ND**	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

If you have any questions concerning this report contact us at the above phone number.

FORM: cFDA.rpt

EDGE ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	**ND**	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	**7.2**	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	**ND**	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	**ND**	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	**ND**	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	**ND**	0.025	0.010	mg/L	200.8	a	
14808-79-8	SULFATE	**4.6**	250	0.2	mg/L	300.0	a	
57-12-5	CYANIDE	**ND**	0.2	0.1	mg/L	OIA-1677-DW	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	**97.0**	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	**ND**	5.00	0.050	mg/L	200.8	a	
7439-97-6	MERCURY	**ND**	0.001	0.0002	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.4	ug/L	524.2	a	
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.4	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.4	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	a	
75-09-2	METHYLENE CHLORIDE (DICHLOROMETHANE)	ND	3	0.4	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	5	0.4	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	a	
E-14471	TOTAL TRIHALOMETHANE	ND	80	0.4	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

EDGE ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.02	ug/L	504.1	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCBs)	ND	0.5	0.5	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
E-10253	TOTAL RECOVERABLE PHENOLICS	ND	0.001	0.001	mg/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-10139	HYDROGEN ION (pH)	**6.37**			pH Units	150.1	a	Temp (C) : 21.3
E-11712	COLOR	**ND**	15	5	COLOR UNIT	SM2120 B	a	pH: 6
E-11734	ODOR	**ND**	3	0	TON	SM2150	a	Temperature: 39.1
E-10617	TURBIDITY	**ND**	1	0.10	NTU	180.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
NA	HAA(5)	**ND**	60	0	ug/L	552.3	a	
15541-45-4	BROMATE	**0.0045**	0.010	0.001	mg/L	300.1	a	
10049-04-4	CHLORINE DIOXIDE	**ND**		0.10	mg/L	SM4500-ClO2 D	a	
7758-19-2	CHLORITE	**ND**	1.00	0.010	mg/L	300.1	a	
	CHLORAMINES TOTAL	**ND**	4.0	0.05	mg/L	SM4500-Cl G	a	
7782-50-5	FREE CHLORINE RESIDUAL	**ND**	0.1	0.05	mg/L	SM4500-Cl G	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

ANALYTICAL

Reference Number: **22-07683**
Lab Number: 14783
Report Date: 04/14/2022

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	**ND**	15	3	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	**ND**	50	4	pCi/L	900.0		
13982-63-3	RADIUM 226	**ND**		1	pCi/L	903.1		
15262-20-1	RADIUM 228	**ND**	5	1	pCi/L	904.0		
7440-61-1	URANIUM	**ND**	0.030	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

EDGE ANALYTICAL

Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - **800.755.9295** • 360.757.1400

Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Data Report

Client Name: Mountain Mist
5410 189th Street E
Puyallup, WA 98375

Reference Number: **22-07683**
Project: FDA Annual Product - Finished Product Spring

Report Date: 4/14/22

Date Received: 3/2/22
Approved by: anp,crc
Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Sample Description: FDA Annual Product Mountain Mist Finished Product - Spring — Matrix BP — Sample Date: 3/7/22 10:07 am
Lab Number: 14783 — Sample Comment: — Collected By:

CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	**CALCIUM**	11.4	0.5	0.03	mg/L	1.0	200.7	a	3/17/22	BJ	200.7_220317A	
7439-95-4	**MAGNESIUM**	5.5	0.5	0.04	mg/L	1.0	200.7	a	3/17/22	BJ	200.7_220317A	
E-11778	**HARDNESS as Calcium Carbonate**	51.1	3.3	0.23	mg/L	1.0	200.7	a	3/17/22	BJ	200.7_220317A	
7440-23-5	**SODIUM**	5.2	0.5	0.05	mg/L	1.0	200.7	a	3/17/22	BJ	200.7_220317A	
7440-09-7	**POTASSIUM**	1.2	1.0	0.02	mg/L	1.0	200.7	a	3/17/22	BJ	200.7_220317A	
E-10184	**ELECTRICAL CONDUCTIVITY**	130	10		uS/cm	1.0	SM2510 B	a	3/9/22	ADL	EC_220309R	

Notes:
ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.