

Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,
An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

MOUNTAIN MIST

“Mountain Mist Spring Finished Product”

on April 3, 2024, according to the FDA testing requirements for bottled drinking water.
All parameters were found to be in compliance with 21 CFR 165 and 21 CFR 129
published limits for bottled drinking water.



A handwritten signature in blue ink, appearing to read "Lawrence J. Hendon".

Director of Laboratories, Vice President

24-05150



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Ct Ste A2 - Wilsonville, OR 97070 - 503.862.7802

Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Mountain Mist
 PO BOX 44427
 Tacoma, WA 98448

Reference Number: **24-05150**

Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Project: FDA Annual Product - Spring w/ SOCs
 Field ID: FDA Annual Product
 Sample Description: Mountain Mist Spring Finished Product
 Sampled By:
 Sample Date: 02/28/2024

Lab Number: 10221
 Report Date: 04/03/2024
 Sampled Comment: 1G
 Approved By: anp,bj,ma,mcs,pdm,tjb

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	0.0020	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	a	
57-12-5	CYANIDE	ND	0.2	0.005	mg/L	OIA-1677-DW	a	
16984-48-8	FLUORIDE	ND	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0001	mg/L	200.8	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	2.30	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE+NITRITE as N	2.30	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.

If you have any questions concerning this report contact us at the above phone number.



Reference Number: **24-05150**

Lab Number: **10221**

Report Date: **04/03/2024**

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 2 of 7

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	5.7	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.001	mg/L	200.8	a	
14808-79-8	SULFATE	4.6	250	0.2	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	89	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.00	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.5	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.5	ug/L	524.2	a	
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.5	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.5	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.5	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.5	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.5	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.5	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.5	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.5	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.5	ug/L	524.2	a	
75-09-2	METHYLENE CHLORIDE (DICHLOROMETHANE)	ND	3	0.5	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.5	ug/L	524.2	a	
95-50-1	O - DICHLOROBENZENE	ND	600	0.5	ug/L	524.2	a	
106-46-7	P - DICHLOROBENZENE	ND	75	0.5	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.5	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	5	0.5	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.5	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.5	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.5	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.5	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.5	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.5	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.5	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.5	ug/L	524.2	a	
E-14471	TOTAL TRIHALOMETHANE	ND	80	0.5	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
96-18-4	1,2,3 - TRICHLOROPROPANE	ND	21	0.5	ug/L	504.1	a	
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.02	ug/L	504.1	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCBs)	ND	0.5	0.5	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
1746-01-6	DIOXIN (2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN)	ND	30	5	pg/L	1613		Analyzed by PACE_MN
85-00-7	DIQUAT	ND	20	0.4	ug/L	549.2	a	
145-73-3	ENDOTHALL	ND	100	9	ug/L	548.1	a	
1071-83-6	GLYPHOSATE	ND	700	6	ug/L	547	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
E-10253	TOTAL RECOVERABLE PHENOLICS	ND	0.001	0.001	mg/L	420.4		Analyzed by Eurofins Pom CA

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.



Reference Number: **24-05150**

Lab Number: 10221

Report Date: 04/03/2024

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 5 of 7

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-10139	HYDROGEN ION (pH)	6.65			pH Units	150.1	a	Temp (C): 19.9
E-11712	COLOR	ND	15	5	COLOR UNIT	SM2120 B	a	pH: 7
E-11734	ODOR	ND	3	0	TON	SM2150	a	Temperature: 40.0 C
E-10617	TURBIDITY	ND	1	0.10	NTU	180.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit.



Reference Number: **24-05150**

Lab Number: 10221

Report Date: 04/03/2024

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 6 of 7

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
NA	HAA(5)	ND	60		ug/L	552.3	a	
15541-45-4	BROMATE	0.0032	0.010	0.001	mg/L	300.1	a	
10049-04-4	CHLORINE DIOXIDE	ND		0.10	mg/L	SM4500-ClO2 D	a	
7758-19-2	CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
	CHLORAMINES TOTAL	ND	4.0	0.05	mg/L	SM4500-Cl G	a	
7782-50-5	FREE CHLORINE RESIDUAL	ND	4.0	0.05	mg/L	SM4500-Cl G	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit.



Reference Number: **24-05150**

Lab Number: 10221

Report Date: 04/03/2024

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 7 of 7

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	3	pCi/L	900.0		Analyzed by PacePA
12587-47-2	GROSS BETA	ND	50	4	pCi/L	900.0		
13982-63-3	RADIUM 226	ND		1	pCi/L	903.1		
15262-20-1	RADIUM 228	ND	5	1	pCi/L	904.0		
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd. Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Data Report

Client Name: Mountain Mist
 PO BOX 44427
 Tacoma, WA 98448

Reference Number: **24-05150**
 Project: FDA Annual Product - Spring
 w/ SOCs

Report Date: 4/3/24

Date Received: 2/27/24

Approved by: anp,bj,jln

Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Sample Description: FDA Annual Product Mountain Mist Spring Finished Product								Matrix	BP	Sample Date: 2/28/24 10:11 am			
Lab Number: 10221		Sample Comment: 1G						Collected By:					
CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Prepped	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	11.0	0.5	0.03	mg/L	1.0	200.7	a		3/13/24	BJ	200.7_240313A4	
E-11778	HARDNESS as Calcium Carbonate	48.5	3.3	0.23	mg/L	1.0	200.7	a		3/13/24	BJ	200.7_240313A4	
7439-95-4	MAGNESIUM	5.1	0.5	0.04	mg/L	1.0	200.7	a		3/13/24	BJ	200.7_240313A4	
7440-09-7	POTASSIUM	1.4	1.0	0.02	mg/L	1.0	200.7	a		3/13/24	BJ	200.7_240313A4	
7440-23-5	SODIUM	5.6	0.50	0.05	mg/L	1.0	200.7	a		3/13/24	BJ	200.7_240313A4	
E-10184	ELECTRICAL CONDUCTIVITY	125	10		uS/cm	1.0	SM2510 B	a		2/29/24	ATH	EC_240229R	
68583-22-2	E. COLI	NEG	Y/N		per 100mL	1.0	SM9223 B/Colilert-18	b	2/28/24 12:10	2/29/24	MLP	m_240228a	
Coli-To-t	TOTAL COLIFORM	ABSENT	P/A		per 100mL	1.0	SM9223 B/Colilert-18	b	2/28/24 12:10	2/29/24	MLP	m_240228a	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
 D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.